

Notified Body No. 1121

**EUROPEAN COMMUNITY CERTIFICATE OF CONFORMITY**

Issued in accordance with the  
**MARINE EQUIPMENT DIRECTIVE**

**Certificate No. 164.106/1121/WCL MED0529QA**

This is to certify that in compliance with the Council Directive 2014/90/EU of 23 July 2014 on marine equipment and the Commission Implementing Regulation 2017/306/EU of 6<sup>th</sup> February 2017, as amended, the product detailed below has been tested in accordance with the appropriate international instruments contained therein.

This certificate is issued to:

**F Ball and Co. Ltd.  
Station Road, Cheddleton, Leek,  
Staffordshire, ST13 7RS, UK**

To certify also that a Surveyor representing Warringtonfire did at their request attend at the works of F Ball and Co Ltd. on the 8<sup>th</sup> January 2014 and annually thereafter for the purpose of examining the production and factory production control systems for this product.

**Product Description** - Deep section compound primary deck covering  
**Product Type** - Primary deck covering (Item Number MED/3.1)  
**Reference** - "Stopgap 600 Base"  
**Modules used** - (D)

The particulars of which are given on this certificate, to verify compliance with the requirements of the International Convention for the Safety of Life at Sea (SOLAS) 1974 Regulation II-2/4, II-2/6 and X/3.

The manufacturer is allowed to affix the U.S. Coast Guard approval number 164.106/1121/WCL MED0529 as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment" signed October 17<sup>th</sup>, 2005.



P Duggan  
Manager  
Warringtonfire  
Holmesfield Road  
Warrington WA1 2DS

Date of Issue: 21<sup>st</sup> February 2019  
This certificate is valid until: 20<sup>th</sup> February 2024

**EC Distinguishing No. 1121**

Certificate No. 164.106/1121/WCL MED0529QA

**Description of Product as Prototype Tested:**

The product is constructed as described in the test reports referenced in the following certificate.

<b>EC Type-Examination Certificate No.</b>	<b>Notified Body</b>	<b>Date of Issue</b>
164.106/1121/WCL MED0529TE	Warringtonfire	21 <sup>st</sup> February 2019

<b>Regulation No</b>	<b>Testing Standard</b>	<b>Result</b>	<b>Report and Date</b>
II-2/4, II-2/6, X/3 and IMO MSC/Circ.1120 ,	IMO Resolution MSC 307(88), Annex 1: Part 5	Pass	WF 407974 and WF 407975, formal and indicative Surface Flammability tests to IMO Resolution MSC 307(88) Annex 1: Part 5. Tested January 2019.
	IMO Resolution MSC 307(88), Annex 1: Part 2	Pass	Smoke and Toxicity is satisfied by meeting the total heat release ( $Q_t$ ) and peak heat release ( $Q_p$ ) as stated in IMO Fire Test Procedures Code, Annex 2 Section 2.2.

**Marking & Identification affixed to the product:**

<b>Manufacturer Name</b>	<b>F Ball and Co. Ltd.</b>
<b>Manufacturer Address</b>	<b>Station Road, Cheddleton, Leek, Staffordshire, ST13 7RS, UK</b>
<b>Product Reference</b>	<b>"Stopgap 600 Base"</b>
<b>Approved Authority</b>	<b>Warringtonfire</b>

Warringtonfire  
Holmesfield Road  
Warrington WA1 2DS

**EC Distinguishing No. 1121**